


Test Report

Document QF : 2501
Page 1 of 3

Issued To Anees School Site No.1, Sector-69, SAS Nagar Mohali	Sample Reg. No. :E01-2306030095 Sample Reg. Date :03-06-2023 Report Date :07-06-2023 Report No. :ICE-2306070324 (1) NABL ULR No. :TC592623000007461F Customer Ref. No. :TRF Letter Dated :03.06.2023
---	---

Test Report as per IS:BIS Specification IS:10500-2012	With Amendment No.(s):01 to 04
---	--------------------------------

PART A : PARTICULARS OF SAMPLE SUBMITTED

a)	Nature of Sample#	Drinking Water
b)	Sample Condition	Good
c)	Grade / Variety / Type / Class / Size etc.	NA
d)	Brand Name	NA
e)	Declared Values,if any	NA
f)	Code No.	
g)	Batch Number#	NA
h)	D.O.M#	NA
i)	Date of Expiry#	NA
j)	Sample Quantity#	2x1 Ltr
k)	Batch Size/Location#	NA
l)	Mode of Packing	Packed in bottle
m)	Date of Receipt	03-06-2023
n)	Date of Start	03-06-2023
o)	Date of Completion	07-06-2023
p)	Seal (Intact/Not Intact/Unsealed)	NA
q)	IO'S Signature (Signed/Unsigned)	Unsigned
r)	Any Other Information	NA


07-06-2023
Deepika Heera
[Authorized Signatory]


Vikrant
07-06-2023
Reviewer


07-06-2023
PremKumar
[Authorized Signatory]

Disclaimer :

- The report is only for the sample tested.
- Total liability of ITC Labs is limited to the invoiced amount.
- The test report shall not be reproduced except in full without the written approval of the laboratory.
- If samples not consumed during analysis, it will be stored and retain as per company policy.
- Samples not drawn by us unless otherwise stated.
- Test report in full or parts shall not be used for promotional or publicity purposes.
- Legal disputes are subjected to Panchkula Jurisdiction only.

Test Report

Document OF : 2501
Page 2 of 3

Issued To Anees School Site No.1, Sector-69, SAS Nagar Mohali	Sample Reg. No. :E01-2306030095 Sample Reg. Date :03-06-2023 Report Date :07-06-2023 Report No. :ICE-2306070324 (1) NABL ULR No. :TC592623000007461F Customer Ref. No. :TRF Letter Dated :03.06.2023
---	---

s)	Test Request Submitted By	Anees School-Mohali (Punjab)
t)	Manufactured By#	NA
u)	Supplied By#	NA


PART B : SUPPLIMENTARY INFORMATIONS

a.	Reference to sampling procedure, whenever applicable	: N/A
b.	Supporting documents for the measurement taken and results derived like graphs, tables, sketches and / or photographs as appropriate to test reports, if any	: N/A
c.	Deviation from the test methods as prescribed in relevant ISS/WORK Instruments, if any	: N/A


Description

Description	Clear Colorless Liquid
-------------	------------------------

S.No.	Parameters	Method	Acceptable Limit	Permissible Limit	Result
Discipline : Chemical					
Group : Water					
1. Organoleptic & Physical Parameter					
a.	Colour (True Colour)	IS 3025 (Part 4) : 2021	5 Max.	15 Max.	2
b.	Taste	IS:3025(Part 8):1984(RA:2017)	Agreeable	Agreeable	Agreeable
c.	Odour	IS: 3025 (P-5)-2018	Agreeable	Agreeable	Agreeable
d.	Turbidity (NTU)	IS:3025(Part 10):1984(RA:2017)	1 Max.	5 Max.	<0.5
e.	pH Value	IS: 3025 (Part-11): 2022	6.5-8.5	No relaxation	8.05


07-06-2023
Deepika Heera
[Authorized Signatory]


Vikrant
07-06-2023
Reviewer


07-06-2023
PremKumar
[Authorized Signatory]

Disclaimer :

- The report is only for the sample tested.
- Total liability of ITC Labs is limited to the invoiced amount.
- The test report shall not be reproduced except in full without the written approval of the laboratory.
- If samples not consumed during analysis, it will be stored and retain as per company policy.
- Samples not drawn by us unless otherwise stated.
- Test report in full or parts shall not be used for promotional or publicity purposes.
- Legal disputes are subjected to Panchkula Jurisdiction only.

Test Report

Document ID : 2501
Page 3 of 3


Issued To Anees School Site No.1, Sector-69, SAS Nagar Mohali		Sample Reg. No. :E01-2306030095 Sample Reg. Date :03-06-2023 Report Date :07-06-2023 Report No. :ICE-2306070324 (1) NABL ULR No. :TC592623000007461F Customer Ref. No. :TRF Letter Dated :03.06.2023			
f.	Total Dissolved Solids,(mg/L)	IS: 3025 (P-16)-1984 (RA 2017)	500 Max.	2000 Max.	342
2. Parameters Concerning Undesirable Substances in excess amount					
a.	Chloride(as Cl)(mg/L)	IS: 3025 (P-32)-1988 (RA2019)	250 Max.	1000 Max.	23
b.	Fluoride as F(mg/L)	IS: 3025 (P-60)-2008 (RA 2019)	1.0 Max.	1.5 Max.	BLQ(LOQ:0.1)
c.	Free Residual Chlorine, (mg/L)	IS: 3025 (P-26): 2021	0.2 Min.	1.0 Max.	Not Applicable
d.	Iron (as Fe)(mg/L)	IS: 3025 (P-53)-2003 (RA 2019)	1.0 Max.	No relaxation	BLQ(LOQ:0.08)
e.	Total Hardness(as CaCO ₃),(mg/L)	IS: 3025 (Part 21)- 2009 (RA 2019)	200 Max.	600 Max.	141

*' represents categories/test parameters not covered under NABL '#' represents Customer Defined Fields


NOTE : NA- Not Applicable, BLQ- Below limit of Quantification, LOQ- Limit of Quantification. Sample Submitted by Customer

REMARKS :The above referred sample of Drinking Water conforms to BIS Specification IS:10500-2012 with upto date amdots with respect to the above tests.

*****End Of Report*****



07-06-2023
Deepika Heera
[Authorized Signatory]



Vikrant
07-06-2023
Reviewer



07-06-2023
PremKumar
[Authorized Signatory]

Interstellar Testing Centre Pvt. Ltd.
86, Industrial Area, Phase-1, Panchkula-134109 (Haryana)
Panchkula-134109 (Haryana)
Phone : (O) 0172-2561543, 2565825
Email : customersupport@itclabs.com
Visit us : www.itclabs.com

Disclaimer :

- The report is only for the sample tested.
- Total liability of ITC Labs is limited to the invoiced amount.
- The test report shall not be reproduced except in full without the written approval of the laboratory.
- If samples not consumed during analysis, it will be stored and retain as per company policy.
- Samples not drawn by us unless otherwise stated.
- Test report in full or parts shall not be used for promotional or publicity purposes.
- Legal disputes are subjected to Panchkula Jurisdiction only.

Test Report

Document QF : 2501

Page 1 of 2

Issued To Anees School Site No.1, Sector-69, SAS Nagar Mohali	Sample Reg. No. :E01-2306030095 Sample Reg. Date :03-06-2023 Report Date :07-06-2023 Report No. :ICE-2306070324 (2) Customer Ref. No. :TRF Letter Dated :03.06.2023
---	--

Test Report as per IS:BIS Specification IS:10500-2012	With Amendment No.(s):01 to 04
---	--------------------------------

PART A : PARTICULARS OF SAMPLE SUBMITTED

a)	Nature of Sample #	Drinking Water
b)	Sample Condition	Good
c)	Grade / Variety / Type / Class / Size etc.	NA
d)	Brand Name	NA
e)	Declared Values,if any	NA
f)	Code No.	
g)	Batch Number #	NA
h)	D.O.M #	NA
i)	Date of Expiry #	NA
j)	Sample Quantity #	2x1 Ltr
k)	Batch Size/Location #	NA
l)	Mode of Packing	Packed in bottle
m)	Date of Receipt	03-06-2023
n)	Date of Start	03-06-2023
o)	Date of Completion	07-06-2023
p)	Seal (Intact/Not Intact/Unsealed)	NA
q)	IO'S Signature (Signed/Unsigned)	Unsigned
r)	Any Other Information	NA
s)	Test Request Submitted By	Anees School-Mohali (Punjab)
t)	Manufactured By #	NA
u)	Supplied By #	NA

PART B : SUPPLIMENTARY INFORMATIONS

a. Reference to sampling procedure, whenever applicable	: N/A
b. Supporting documents for the measurement taken and results derived like graphs, tables, sketches and / or photographs as appropriate to test reports, if any	: N/A
c. Deviation from the test methods as prescribed in relevant ISS/WORK Instruments, if any	: N/A

Description	
Description	Clear Colorless Liquid

Test Report

Document QF : 2501

Page 2 of 2

Issued To Anees School Site No.1, Sector-69, SAS Nagar Mohali	Sample Reg. No. :E01-2306030095 Sample Reg. Date :03-06-2023 Report Date :07-06-2023 Report No. :ICE-2306070324 (2) Customer Ref. No. :TRF Letter Dated :03.06.2023
---	--

S.No.	Parameters	Method	Acceptable Limit	Permissible Limit	Result
Discipline : Biological					
Group : Water					
1.	Microbiological Tests				
a.	E. Coli	IS 15185: 2016	Shall not be detectable in any 100 ml sample	No Relaxation	Absent/100ml
b.	Total Coliform	IS 15185: 2016	Shall not be detectable in any 100 ml sample	No Relaxation	Absent/100ml

'#' represents Customer Defined Fields

NOTE : NA- Not Applicable, BLQ- Below limit of Quantification, LOQ- Limit of Quantification. Sample Submitted by Customer

REMARKS :The above referred sample of Drinking Water conforms to BIS Specification IS:10500-2012 with upto date amdots with respect to the above tests.

*******End Of Report*******